



liftinstituut
SINCE 1933



EU-TYPE EXAMINATION CERTIFICATE

Issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Decree no. 2018-0000125182

Certificate no.	: NL17-400-1002-186-02	Revision no.:	5
Description of the product	: Lift control unit for electric or hydraulic lifts with monitoring circuit for safety chain, door bridging circuit, detection of uncontrolled movement of the car (UCMP) and brake monitoring (ACOP/UCMP)		
Trademark	: Safeline Sweden AB		
Type no.	: THOR NX-T, SB and SZ board		
Name and address of the manufacturer	: SafeLine Sweden AB Antennvägen 10 SE135 48, Tyresö, Sweden		
Name and address of the certificate holder	: SafeLine Sweden AB Antennvägen 10 SE135 48, Tyresö, Sweden		
Certificate issued on the following requirements	: Lifts Directive 2014/33/EU		
Certificate based on the following standard	: EN 81-20:2020, clause 5.6.6.2, 5.6.7.3, 5.6.6.7, 5.6.7.9, 5.11.1, 5.11.2.1.2 and 5.11.2.3 EN 81-50:2020, clause 5.8 and 5.15		
Test laboratory	: None		
Date and number of the laboratory report	: None		
Date of EU-type examination	: November 2015 – February 2017; Rev.1; December 10, 2018 Rev.2; July 4, 2019; Rev.3; November 2019; Rev.4; July 28, 2020; Rev.5; June - September 2021		
Additional document with this certificate	: Report belonging to the EU type-examination certificate no.: NL17-400-1002-186-02 rev.5		
Additional remarks	: Key parameters for detecting UCM Detection distance: installed door-zone (variable) Max. response time THOR NX-T : 22ms Speed and distance travelled : to be calculated		
Conclusion	: The safety component meets the requirements of the Lifts Directive 2014/33/EU taking into account any additional remarks mentioned above.		

Amsterdam

Date : 06-10-2021
Valid until : 06-10-2026

ing A.J. van Ommen
International Business
Manager

Certification decision by